



- NOTES:-
1. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE SPECIFIED.
 2. MINIMUM SAFETY CLEARANCES FOR 72.5 kV AS PER IEC 61936
 - a) phase to earth - 630 mm
 - b) phase to phase - 630 mm
 - c) ground safety clearance - 2250 mm
 - d) ground to live conductor - 2880 mm
 - e) At perimeter fence - 2130 mm Horizontal

Rev.	Revision note	Date	Name	Prepared	2024.12.24	Senthil Kumar J	Title	Substation Layout	Doc. kind	Layout drawing	Scale	1:100			
A	PASS Updated	2025.01.23	JSK	Approved	2024.12.24	Seppo Pasto				DCC ELD	Size	A2			
B	MEHO Updated	2025.02.13	M.A	Project	7124255 49Komma8 AG, Bonaduz BESS 50kV PASS Substation, Switzerland				Resp. dept.	FIPGGI	Rev. ind.	B		Language	EN
															n. sheet
							HITACHI	Hitachi Energy Finland Oy	Doc. no.	7124255 T2 F8101			Sheet	1	